

CDS Systems
Penbwch Isaf Farm
Penycoedcae Road
Pontypridd CF37 1PU

T: 01443 405052
F: 01443 405061
E: info@cdssystemss.co.uk

Certificate of Electrical Appliance Testing

Certificate Number 29981

PAT Certificate issued to

Nathan Britton

NJB EVENTS 4 Deere
Road, Crown Hill
Llantwit Fardre
CF38 2NL

Sound & Lighting Equipment

Certificate Valid until 12/10/2018

The electrical appliances at these premises have been tested (as per the current Appliance Register) have been inspected and tested for electrical safety to the Requirements of the Electricity at Work Regulations

Test results for individual appliances are available on request



Test carried out by:

CDS Systems
Penbwch Isaf Farm
Penycoedcae Road
Pontypridd
CF37 1PU

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE



CLIENT: NJB Events/Nathan Britton PHONE : 01443 205417

TEST EQUIPMENT USED Fluke 6200-2-UK SERIAL NO.4628912

TESTED BY.....L.Owens.....

CERTIFICATE NO. 0029981

RE-TEST DATE 12/10/18

Asset No.	Make & Model	Location	Voltage	Rating	Fuse Rating	Insulation Resistance	Earth Continuty	Plug, Flex & Body Ok	Passed
8001	RCF 415 Active Speaker	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8002	RCF 415 Active Speaker	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8003	RCF 905 AS Active SubSpeaker	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8004	RCF 905 AS Active SubSpeaker	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8005	Apple Macbook Pro Laptop PSU	Mobile	230V	10	10	>20MΩ	Class 2	√	√
8006	Samsung RF511 Laptop PSU	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8007	Stairville mh-x50	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8008	Stairville mh-x50	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8009	Stairville mh-250	Mobile	230V	5	5	>20MΩ	0.07Ω	√	√
8010	Stairville mh-250	Mobile	230V	5	5	>20MΩ	0.06Ω	√	√
8011	Eurolite LS200 LED Spot Unit	Mobile	230V	3	3	>20MΩ	0.04Ω	√	√
8012	Eurolite LS200 LED Spot Unit	Mobile	230V	3	3	>20MΩ	0.08Ω	√	√
8013	ADJ TriPar Profile LED	Mobile	230V	0.5	0.5	>20MΩ	0.02Ω	√	√
8014	ADJ TriPar Profile LED	Mobile	230V	0.5	0.5	>20MΩ	0.03Ω	√	√
8015	ADJ TriPar Profile LED	Mobile	230V	0.5	0.5	>20MΩ	0.07Ω	√	√
8016	ADJ TriPar Profile LED	Mobile	230V	0.5	0.5	>20MΩ	0.04Ω	√	√
8017	ADJ TriPar Profile LED	Mobile	230V	0.5	0.5	>20MΩ	0.05Ω	√	√
8018	ADJ TriPar Profile LED	Mobile	230V	0.5	0.5	>20MΩ	0.07Ω	√	√
8019	ADJ TriPar Profile LED	Mobile	230V	0.5	0.5	>20MΩ	0.05Ω	√	√
8020	ADJ TriPar Profile LED	Mobile	230V	0.5	0.5	>20MΩ	0.05Ω	√	√

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE



CLIENT: NJB Events/Nathan Britton PHONE : 01443 205417

TEST EQUIPMENT USED Fluke 6200-2-UK SERIAL NO.4628912

TESTED BY.....L.Owens.....

CERTIFICATE NO. 0029981

RE-TEST DATE 12/10/18

Asset No.	Make & Model	Location	Voltage	Rating	Fuse Rating	Insulation Resistance	Earth Continuty	Plug, Flex & Body Ok	Passed
8021	American DJ Radiums 1000	Mobile	230V	1.5	1.5	>20MΩ	0.02Ω	√	√
8022	American DJ Radiums 1000	Mobile	230V	1.5	1.5	>20MΩ	0.02Ω	√	√
8023	American DJ Radiums 1000	Mobile	230V	1.5	1.5	>20MΩ	0.02Ω	√	√
8024	Showtec Pixel Square (1)	Mobile	230V	3	3	>20MΩ	0.08Ω	√	√
8025	Showtec Pixel Square (2)	Mobile	230V	3	3	>20MΩ	0.07Ω	√	√
8026	Showtec 50 Moving Head	Mobile	230V	3	3	>20MΩ	0.06Ω	√	√
8027	Showtec 50 Moving Head	Mobile	230V	3	3	>20MΩ	0.06Ω	√	√
8028	LEDJ Colour Storm RGB	Mobile	230V	2	2	>20MΩ	0.02Ω	√	√
8029	LEDJ Colour Storm RGB	Mobile	230V	2	2	>20MΩ	0.04Ω	√	√
8030	LEDJ Colour Storm RGB	Mobile	230V	2	2	>20MΩ	0.03Ω	√	√
8031	LEDJ Colour Storm RGB	Mobile	230V	2	2	>20MΩ	0.02Ω	√	√
8032	Chauvet Intimidator	Mobile	230V	3	3	>20MΩ	0.05Ω	√	√
8033	Chauvet Intimidator	Mobile	230V	3	3	>20MΩ	0.09Ω	√	√
8034	Chauvet Haze 2D	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8035	Stage Line LED-812DMX	Mobile	230V	5	5	>20MΩ	0.06Ω	√	√
8036	Stage Line LED-812DMX	Mobile	230V	1	1	>20MΩ	0.06Ω	√	√
8037	4 Way Black Extention	Mobile	230V	13	13	>20MΩ	0.08Ω	√	√
8038	4 Way Black Extention	Mobile	230V	13	13	>20MΩ	0.08Ω	√	√
8039	4 Way Black Extention	Mobile	230V	13	13	>20MΩ	0.07Ω	√	√
8040	6 Way Grey Extention	Mobile	230V	13	13	>20MΩ	0.04Ω	√	√

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE



CLIENT: NJB Events/Nathan Britton PHONE : 01443 205417

TEST EQUIPMENT USED Fluke 6200-2-UK SERIAL NO.4628912

TESTED BY.....L.Owens.....

CERTIFICATE NO. 0029981

RE-TEST DATE 12/10/18

Asset No.	Make & Model	Location	Voltage	Rating	Fuse Rating	Insulation Resistance	Earth Continuty	Plug, Flex & Body Ok	Passed
8041	6 Way Grey Extention	Mobile	230V	13	13	>20MΩ	0.06Ω	√	√
8042	6 Way Grey Extention	Mobile	230V	13	13	>20MΩ	0.08Ω	√	√
8043	9 Way Black Extention	Mobile	230V	13	13	>20MΩ	0.06Ω	√	√
8044	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8045	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8046	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8047	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8048	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8049	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8050	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8051	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8052	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8053	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8054	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8055	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8056	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8057	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8058	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8059	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8060	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE



CLIENT: NJB Events/Nathan Britton PHONE : 01443 205417

TEST EQUIPMENT USED Fluke 6200-2-UK SERIAL NO.4628912

TESTED BY.....L.Owens.....

CERTIFICATE NO. 0029981

RE-TEST DATE 12/10/18

Asset No.	Make & Model	Location	Voltage	Rating	Fuse Rating	Insulation Resistance	Earth Continuty	Plug, Flex & Body Ok	Passed
8061	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8062	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.07Ω	√	√
8063	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.08Ω	√	√
8064	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8065	IEC Power Cable	Mobile	230V	3	3	>20MΩ	0.06Ω	√	√
8066	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8067	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8068	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8069	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8070	IEC Power Cable	Mobile	230V	3	3	>20MΩ	0.06Ω	√	√
8071	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8072	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8073	IEC Power Cable	Mobile	230V	3	3	>20MΩ	0.03Ω	√	√
8074	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8075	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8076	IEC Power Cable	Mobile	230V	3	3	>20MΩ	0.04Ω	√	√
8077	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8078	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.06Ω	√	√
8079	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.03Ω	√	√
8080	IEC Power Cable	Mobile	230V	5	5	>20MΩ	0.08Ω	√	√

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE



CLIENT: NJB Events/Nathan Britton PHONE : 01443 205417

TEST EQUIPMENT USED Fluke 6200-2-UK SERIAL NO.4628912

TESTED BY.....L.Owens.....

CERTIFICATE NO. 0029981

RE-TEST DATE 12/10/18

Asset No.	Make & Model	Location	Voltage	Rating	Fuse Rating	Insulation Resistance	Earth Continuty	Plug, Flex & Body Ok	Passed
8081	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8082	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8083	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8084	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8085	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8086	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8087	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8088	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8089	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.05Ω	√	√
8090	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8091	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8092	Accu Pad 7 Battery Uplight	Mobile	230V	5	5	>20MΩ	0.04Ω	√	√
8093	Stairville MH-X60 Moving Head	Mobile	230V	3.5	5	>20MΩ	0.03Ω	√	√
8094	Stairville MH-X60 Moving Head	Mobile	230V	3.5	5	>20MΩ	0.04Ω	√	√
8095	Stairville MH-X60 Moving Head	Mobile	230V	3.5	5	>20MΩ	0.03Ω	√	√
8096	Stairville MH-X60 Moving Head	Mobile	230V	3.5	5	>20MΩ	0.04Ω	√	√
8097	Equinox Booth LED Stair cloth	Mobile	230V	500mA	500mA	>20MΩ	0.03Ω	√	√
8098	Equinox Booth LED Stair cloth	Mobile	230V	500mA	500mA	>20MΩ	0.03Ω	√	√
8099	Showtec Power Shot	Mobile	230V	1	1	>20MΩ	0.02Ω	√	√
8100	Showtec Power Shot	Mobile	230V	1	1	>20MΩ	0.02Ω	√	√

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE



CLIENT: NJB Events/Nathan Britton PHONE : 01443 205417

TEST EQUIPMENT USED Fluke 6200-2-UK SERIAL NO.4628912

TESTED BY.....L.Owens.....

CERTIFICATE NO. 0029981

RE-TEST DATE 12/10/18

Asset No.	Make & Model	Location	Voltage	Rating	Fuse Rating	Insulation Resistance	Earth Continuty	Plug, Flex & Body Ok	Passed
8101	IEC/DMX Combination Lead 5mt	Mobile	230V	6	5	>20MΩ	0.03Ω	√	√
8102	IEC/DMX Combination Lead 5mt	Mobile	230V	6	5	>20MΩ	0.03Ω	√	√
8103	IEC/DMX Combination Lead 5mt	Mobile	230V	6	5	>20MΩ	0.03Ω	√	√
8104	IEC/DMX Combination Lead 5mt	Mobile	230V	6	5	>20MΩ	0.04Ω	√	√
8105	IEC/DMX Combination Lead 5mt	Mobile	230V	6	5	>20MΩ	0.03Ω	√	√
8106	IEC/DMX Combination Lead 5mt	Mobile	230V	6	5	>20MΩ	0.03Ω	√	√
8107	IEC/DMX Combination Lead 10mt	Mobile	230V	6	5	>20MΩ	0.05Ω	√	√
8108	IEC/DMX Combination Lead 10mt	Mobile	230V	6	5	>20MΩ	0.06Ω	√	√
8109	IEC/DMX Combination Lead 10mt	Mobile	230V	6	5	>20MΩ	0.05Ω	√	√
8110	IEC/DMX Combination Lead 10mt	Mobile	230V	6	5	>20MΩ	0.05Ω	√	√
8111	42" Samsung TV	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8112	42" LG TV	Mobile	230V	5	5	>20MΩ	0.02Ω	√	√
8113	RCF EVOX 8 Speaker	Mobile	230V	3.15	3.15	>20MΩ	0.02Ω	√	√
8114	RCF EVOX 8 Speaker	Mobile	230V	3.15	3.15	>20MΩ	0.02Ω	√	√
8115	RCF EVOX 12 Speaker	Mobile	230V	3.15	3.15	>20MΩ	0.03Ω	√	√
8116	RCF EVOX 12 Speaker	Mobile	230V	3.15	3.15	>20MΩ	0.02Ω	√	√
8117	RCF 408 Speaker	Mobile	230V	3.15	3.15	>20MΩ	0.03Ω	√	√
8118	Thomann Box122 Speaker	Mobile	230V	2.5	2.5	>20MΩ	0.04Ω	√	√
8119	Thomann Box122 Speaker	Mobile	230V	2.5	2.5	>20MΩ	0.04Ω	√	√
8120	Stairville LED Ball	Mobile	230V	500mA	500mA	>20MΩ	0.04Ω	√	√

